

DOOR RELEASE HARDWARE

PURPOSE

To provide an alternative solution to limit the probability of residents in treatment and care occupancies with safety restrictions exiting a building or supervised area and exposing themselves or others to undue risks.

DISCUSSION

Residents in treatment and care occupancies, with memory related condition or disorders may be subject to harm by wandering away from supervised areas without staff being aware that the resident has exited the supervised floor area or building. Often the resident will leave through an emergency exit. If the door is not alarmed then staff are unaware the patient has left the area or the building. If the door is alarmed then the fire alarm system is set off causing an automatic signal to the local fire department resulting in costly nuisance alarms. Currently systems are being installed which may be unsafe and non-compliant that restrict egress and create a risk to life safety.

The Alberta Building Code 2014 (ABC 2014) has allowances for using electromagnetic locks on exit doors provided that these locks release within 15 seconds of actuation. These provisions have also been applied to existing buildings whose operation and modification are regulated by the Alberta Fire Code 2014 (AFC 2014).

The National Building Code of Canada 2015 (NBC 2015) includes a new Sentence 3.4.6.16.(5) with specific conditions related to using electromagnetic locking devices in Treatment-Group B, Division 2 (B2) and Care-Group B, Division 3 (B3) occupancies. Transparent boxes that set off an audible signal when opened can be installed to cover the manual stations. Also, one optional additional release device (e.g. swipe card device, key pad) can be installed to facilitate the free movement of staff and visitors in the building without setting off the alarm system from the electromagnetic locks.

CODE REFERENCES

ABC 2014 Sentence 3.4.6.16.(1) Door Release Hardware states:

1) Except for devices on doors serving a *contained use area* or an *impeded egress zone* designed to be remotely released in conformance with Article 3.3.1.13., and except as permitted by Sentence (4) and Article 3.4.6.17., locking, latching and other fastening devices on a principal entrance door to a *building* as well as on every *exit* door shall permit the door to be readily opened from the inside with not more than one releasing operation and without requiring keys, special devices or specialized knowledge of the door opening mechanism. (See Appendix A.)

Unless stated otherwise, all Code references in this STANDATA are to Division B of the Alberta Building Code 2014.

Issue of this STANDATA is authorized by
the Building and Fire Administrators

[Original Signed]
Paul Chang

[Original Signed]
Kevan D. Jess



This item has been replaced by a more recent resource or the content may be otherwise out of date.
It is provided for informational and research purposes.



Archived

ABC 2014 Sentence 3.2.4.8.(4) Signals to Fire Department states:

4) Notification of the fire department, as required by Sentences (1), (2) and (3), shall be provided in conformance with CAN/ULC-S561, "Installation and Services for Fire Signal Receiving Centres and Systems." (See Appendix A.)

NBC 2015, Sentence 3.4.6.16.(5) Door Release Hardware states:

5) Electromagnetic locks that do not incorporate latches, pins or other similar devices to keep the door in the closed position are permitted to be installed on doors in Group B, Division 2 and Division 3 occupancies, provided

- a) the building is
 - i) equipped with a fire alarm system, and
 - ii) sprinklered,
- b) the electromagnetic lock releases upon
 - i) actuation of the alarm signal from the building's fire alarm system,
 - ii) loss of its power supply and of power to its auxiliary controls,
 - iii) actuation of a manually operated switch that is readily accessible at a constantly attended location within the locked space, and
 - iv) actuation of the manual station installed within 0.5 m of each door and equipped with an auxiliary contact, which directly releases the electromagnetic lock,
- c) upon release, the electromagnetic lock requires manual resetting by actuation of the switch referred to in Subclause (b)(iii),
- d) a legible sign with the words "EMERGENCY EXIT UNLOCKED BY FIRE ALARM" written in letters at least 25 mm high with a stroke at least 5 mm wide is permanently mounted on the door,
- e) the operation of any by-pass switch, where provided for testing of the fire alarm system, sets off an audible signal and a visual signal at the fire alarm annunciator panel and at the monitoring station referred to in Sentence 3.2.4.7.(4), and
- f) emergency lighting is provided at the doors.

(See Note A-3.4.6.16.(5).)

A-3.4.6.16.(5) Electromagnetic Locks in Care and Treatment Occupancies. The installation of electromagnetic locks in care and treatment occupancies requires special provisions to address the compromised condition of residents and the nature of daily operations. Accordingly, to reduce the incidence of false operation by residents, transparent boxes that set off an audible signal when opened can be installed to cover the manual stations. Also, one optional additional release device (e.g. swipe card device, key pad) can be installed to facilitate the free movement of staff and visitors in the building.

APPLICATION

This Variance applies to doors in Group B, Division 2 and Division 3 occupancies.

VARIANCE

This variance, which can be applied to new and existing buildings, provides approximately equivalent or greater safety performance with respect to persons and property as that provided for by the Safety Codes Act, the ABC 2014 and the AFC 2014.

1. Electromagnetic locks that do not incorporate latches, pins or other similar devices to keep the door in the closed position are permitted to be installed on doors in Group B, Division 2 and Division 3 occupancies, provided
 - a) the building is

- i) equipped with a fire alarm system, and
 - ii) sprinklered,
 - b) the electromagnetic lock releases upon
 - i) actuation of the alarm signal from the building's fire alarm system,
 - ii) loss of its power supply and of power to its auxiliary controls,
 - iii) actuation of a manually operated switch that is readily accessible at a constantly attended location within the locked space, and
 - iv) actuation of the manual station installed within 0.5 m of each door and equipped with an auxiliary contact, which directly releases the electromagnetic lock, (these manual stations may be covered with a transparent box that sets off an audible signal when opened).
 - c) upon release, the electromagnetic lock requires manual resetting by actuation of the switch referred to in Subclause (b)(iii),
 - d) a legible sign with the words "EMERGENCY EXIT UNLOCKED BY FIRE ALARM" written in letters at least 25 mm high with a stroke at least 5 mm wide is permanently mounted on the door,
 - e) the operation of any by-pass switch, where provided for testing of the fire alarm system, sets off an audible signal and a visual signal at the fire alarm annunciator panel and at the monitoring station referred to in Sentence 3.2.4.8.(4) of ABC 2014, and
 - f) emergency lighting is provided at the doors.
2. One optional additional release device (e.g. swipe card device, key pad) can be installed to facilitate the free movement of staff and visitors in the building.

This VARIANCE is applicable throughout the province of Alberta.