

OIL AND GAS PROCESSING FACILITIES

PURPOSE

The purpose of this variance is to allow small oil and gas high hazard industrial occupancies to be classified as Group F, Division 2 as an alternative solution under the Alberta Building Code 2014 (ABC 2014).

DISCUSSION

Oil and gas processing buildings are often classified as Group F, Division 1, high hazard industrial occupancies. In this environment, safe work procedures and worker safety training is an important complement to the building's fire protection and suppression systems.

Oil and gas companies have developed guides that describe design and operation practices that support safe working conditions at small, portable oil and gas production facilities, often classified as high hazard industrial occupancies. The objective of these guides is to limit the probability that a person in or adjacent to a facility may be exposed to an unacceptable level of risk of injury or illness.

“[Safety Guidelines for Small, Portable Oil and Gas Production Facilities: Training, Operating and Design Recommendations](#)” is produced by the Canadian Association of Petroleum Producers (CAPP). The guide is intended to supplement other applicable standards and regulatory codes including the ABC 2014. It recommends solutions for safe design, operation and maintenance practices for field facilities including worker training and competency. There are three main areas of focus: process safety, public safety and occupational health and safety. Owners should assess their own requirements to establish design, operating, maintenance, and work.

The implementation of this CAPP guide in addition to other safety conditions described in this variance allow for small oil and gas processing buildings to be classified as Group F, Division 2 occupancies.

CODE REFERENCE

Clause 3.3.1.5.(1)(c) states:

3.3.1.5. Egress Doorways

- 1) Except for *dwelling units*, a minimum of 2 egress doorways located so that one doorway could provide egress from the room or *suite* as required by Article 3.3.1.3. if the other doorway becomes inaccessible to the occupants due to a fire which originates in the room or *suite*, shall be provided for every room and every *suite*
 - c) in a *floor area* that is not *sprinklered* throughout, and
 - i) the area of a room or *suite* is more than the value in Table 3.3.1.5.A., or
 - ii) the travel distance within the room or *suite* to the nearest egress doorway is more than the value in Table 3.3.1.5.A.,

Unless stated otherwise, all Code references in this STANDATA are to Division B of the Alberta Building Code 2014.

Issue of this STANDATA is authorized by the
Provincial Building Administrator

[Original Signed]
Paul Chang


Government



Table 3.3.1.5.A states:

Table 3.3.1.5.A. Egress in Floor Area not Sprinklered Throughout Forming Part of Sentence 3.3.1.5.(1)		
Occupancy of Room or Suite	Maximum Area of Room or Suite, m ²	Maximum Distance to Egress Doorway, m
Group F, Division 2	150	10

APPLICATION

This STANDATA applies to oil or gas processing buildings that are

1. considered as low human occupancy buildings,
2. located outside of urban areas, and
3. used to house oil and gas processing equipment, such as
 - a. compressor stations,
 - b. heater packages,
 - c. pump packages,
 - d. separator packages,
 - e. treater packages,
 - f. dehydrator units,
 - g. field equipment,
 - h. L.P.G. handling facilities,
 - i. refrigeration process units,
 - j. oil batteries, and
 - k. similar types of buildings.

This STANDATA does not apply to residential buildings, office buildings, warehousing and other buildings not specifically used for oil or gas processing even though these buildings may be located on the same site.

VARIANCE

This variance provides approximately equivalent or greater safety performance with respect to persons and property as that provided for by the Safety Codes Act and the ABC 2014.

Oil and gas processing buildings may be classified as Group F, Division 2 occupancy provided:

1. The building does not exceed 150 m² in building area.
2. A risk assessment has been prepared by a registered engineering professional, licensed to practice in the province of Alberta, which includes
 - a. The determination of adequate rates of gravity and/or mechanical ventilation based on
 - i. requirements for electrical area classification and recommendations given in API RP500, "Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities as Class I, Division 1 and Division 2" for normal or continuous operation,
 - ii. a minimum of 6 air changes per hour, or
 - iii. higher ventilation rates where sour gas may be present.
 - b. The installation of combustible and/or toxic gas detection,
 - c. The installation of emergency shut down stations with remote activators,

This item has been replaced by a more recent resource or the content may be otherwise out of date. It is provided for informational and research purposes.



Archived

- d. The installation of listed fire detection equipment (which may include flame detectors in lieu of smoke or heat detectors) to automatically shut down and depressurize the facility, and
- e. The provision of a supply of water for external fire fighting for buildings in remote areas.

Note: The recommendations given by the Registered Engineering Professional are to be listed in the building permit application submission.

3. The appropriate training and procedure measures outlined in the CAPP Guidelines are in place.
4. The following measures, as described by the CAPP Guidelines and the ABC 2014, are incorporated:
 - a. At least two exit doors are installed, equipped with panic hardware, and located remotely from each other where the building exceeds 7.4 m² in building area so that the travel distance to at least one exit from any point in the floor area does not exceed 10 m.
 - b. Buildings that are related functionally or through process may be considered as one building for the purposes of spatial separation between buildings.
 - c. Spatial separation calculations for limiting distances to property lines are calculated as per
 - i. Subsection 3.2.3. of the Alberta Building Code 2014 for Part 3 buildings, or
 - ii. Subsection 9.10.14. of the Alberta Building Code 2014 for Part 9 buildings.
 - d. Portable fire extinguishers are provided in accordance with the Alberta Fire Code 2014.

This VARIANCE applies throughout the province of Alberta.

