

## ERRATA PACKAGE #5

### DISCUSSION

The Alberta Building Code 2006 was adopted on September 2<sup>nd</sup>, 2007 by provincial regulation. The Building Code Amendment Regulation was adopted on March 12<sup>th</sup> 2009 and is declared to be in force on May 3<sup>rd</sup>, 2009. Since that time, Code users and safety codes officers have identified several typographical and technical errors in the document that need to be revised. This STANDATA details the changes identified as of the issuance date above.

The erratum has been approved by the Building Technical Council of the Safety Codes Council. The table on the following page identifies the erratum that applies to the Alberta Building Code 2006. Code users are instructed to make note of this change in their Code books.

---

Unless stated otherwise, all Code references in this STANDATA are to Division B of the Alberta Building Code 2006.

**Government  
of Alberta ■**

Issue of this STANDATA is authorized by  
the Acting Chief Building Administrator

*[Original Signed]*  
Chris Salvian, P.Eng.



SAFETY CODES COUNCIL

## DIVISION B ERRATA

Provision	Current Requirement	Revised Requirement	Justification
3.8.2.1.(2)(g)	<p><b>2)</b> A <i>barrier-free</i> path of travel for persons using wheelchairs is not required</p> <p>...</p> <p>g) to floor levels not served by a passenger elevator, a platform equipped passenger elevating device, an escalator, or an inclined moving walk,</p> <p>...</p>	<p><b>2)</b> A <i>barrier-free</i> path of travel for persons using wheelchairs is not required</p> <p>...</p> <p>g) to <del>floor levels</del> <u>mezzanines</u> not served by a passenger elevator, a platform equipped passenger elevating device, an escalator, or an inclined moving walk,</p> <p>...</p>	Editorial correction.

This ERRATUM applies throughout the Province of Alberta.