



NOTES :

1. The concrete used shall be 28,000 kilopascal (4,000 psi.).
2. Anchor bolts, complete with nut and washer, are to be supplied by the Contractor.
3. These bases shall be finished with 15 mm chamfer on all exposed edge.
4. All figure on dimensions and sizes are in mm unless otherwise indicated.
5. Not to scale.

FIGURE 6

Alberta TRANSPORTATION AND UTILITIES Traffic Operations Branch	DWG. No.	TEB 4.39
	Date	SEPT.15/92
	Revision	
	Revision	

**TYPE "M" PRECAST SIGNAL
CONTROL CABINET BASE**

A.D. Cherwenuk, Director