

2018 CANADIAN ELECTRICAL CODE

SUBJECT: Section 36 – High-voltage installations

Rule 36-308 Connections to the station ground electrode

The boundary of a station located indoors is limited to the equipment and the equipment enclosure. For the purposes of bonding non-current-carrying metal parts inside the building not deemed part of the station, Section 10 applies.

Industry is reminded to consider limiting touch and step potential according to the tolerable levels specified in Table 52.

Issue of this STANDATA is authorized by
the Provincial Electrical Administrator

[Original Signed]
Clarence C. Cormier, P.Eng.

