

2016 ALBERTA ELECTRICAL UTILITY CODE ERRATA

SUBJECT: Re-Introduction of Missing Former Section 10 Code Clause in Section 2

DISCUSSION:

The Alberta Electric Utility Code (AEUC) 2016 was brought into force on May 1, 2017. A clause has been found to be missing from the 2016 AEUC that was previously located in Section 10 of the 2013 Edition. After investigation, it was determined that the clause in question was supposed to have been moved from Section 10 to Section 2 of the code during the AEUC 2016 code review process, however, the latter step of adding the clause to Section 2 of the code was accidentally missed.

CODE REFERENCES:

2013 AEUC (clause removed in 2016 code revision)

10-002 Standard to be Used

CSA Standard C22.3 No.1-15, Overhead Systems, shall be the standard for the construction and maintenance of overhead electrical utility and communication systems, with amendments to that standard as follows:

(5) Amend 4.3 by adding the following:

4.3.7 Operation and Maintenance

- (1) The operator of a utility system shall ensure that the equipment and lines are:
 - (a) not energized unless the equipment and lines meet the requirements of this Standard; and
 - (b) visually inspected at regular intervals, as required; and
 - (c) maintained in accordance with this Standard.
- (2) The operator of an electrical utility system shall ensure that equipment or lines not in use are maintained in accordance with this Standard.
- (3) The operator of communication systems shall ensure that equipment or lines not in use are maintained in accordance with this Standard.

Unless stated otherwise, all Code references in this STANDATA are to the 2016 Alberta Electrical Utility Code.

Issue of this STANDATA is authorized by
the Provincial Electrical Administrator

[Original Signed]

Clarence C. Cormier, P.Eng.


Government

ERRATA

Add:

Rule 2-032 Operation and Maintenance

- (1) The operator of a utility system shall ensure that the equipment and lines are:
 - (a) not energized unless the equipment and lines meet the requirements of this Code; and
 - (b) visually inspected at regular intervals, as required; and
 - (c) maintained in accordance with this Code.
- (2) The operator of an electrical utility system shall ensure that equipment or lines not in use are maintained in accordance with this Code.
- (3) The operator of communication systems shall ensure that equipment or lines not in use are maintained in accordance with this Code.

These ERRATA are applicable throughout the province of Alberta.

Archived